

DECLARATION OF PERFORMANCE
No. 001CPR2013-07-14

1. Unique identification code of the product-type:
Positive pressure air/flue terminal with metal flue duct for C62- and C63-type gas appliances
T120- P1- D-Vm-L40045- O50
2. Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4) of the CPR:
[to be given by the manufacturer]
3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:
convey air for combustion, and the products of combustion from appliances to the outside atmosphere.
4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):
AnyCo Ltd,
PO Box 21
B-1050 Brussels
5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):
[to be given by the manufacturer]
6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:
System 2+
7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:
EN 14989-1: 2007
Notified production control certification body No. 5678 performed the initial inspection of the manufacturing plant and of factory production control and the continuous surveillance, assessment and evaluation of factory production control. and issued the certificate of constancy of conformity of the factory production control.
8. Declared performance

Essential characteristics	Performance	Harmonised technical specification
Compressive strength	Pass	EN 14989-1: 2007
Resistance to fire	050	
Gas tightness/leakage: - of the flue - of the air supply duct	$\leq 0,006 \text{ l s}^{-1} \text{ m}^{-2}$ (under a positive pressure of 200 Pa) $\leq 0,28 \text{ l s}^{-1} \text{ m}^{-2}$ (under a positive pressure of 40 Pa)	
Flow resistance coefficient: - of the flue - of the air supply duct	1,5 (declared) 2,5 (declared)	
Thermal resistance of air/flue terminal: - with separate air/flue configuration - with concentric air/flue configuration	0,5 m²K/W (declared) 0,35 m²K/W (declared)	
Thermal shock	Pass	
Flexural tensile strength	Pass	
Durability: - against chemicals - against corrosion - freeze thaw	Pass Pass Pass	

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4. Signed for and on behalf of the manufacturer by:

.....
(name and function)

.....
(place and date of issue)

.....
(signature)